

Memo

To: Bryan Myrkle, Community Development Director

From: Amy E. Gilson, P.E., Director of Public Works

Date: August 26, 2015

Re: Hope Landing 1146 N. Cochran Expansion

We have reviewed the site plan for the above mentioned project as it relates to our standards and codes, and offer the following comments:

Please add notes that water and sewer connections must be inspected by City staff, and a minimum 24 hour notice is required.

The fire line tap shall be a live tap by the contractor and witnessed by the DPW. A minimum 24 hour notice is required.

Sewer and water equity fees are required to be paid prior to construction beginning.

A permit may be required from the Michigan Department of Transportation.

A permit may be required from the county drain commissioner.