

Memo

To: Bryan Myrkle, Community Development
From: Amy E. Gilson, P.E., Director of Public Works
Date: December 5, 2016
Re: Linn Products Plant #2



We have reviewed the above referenced site plan as it relates to our standards and codes, and offer the following comments:

An inspection manhole must be placed on the sanitary sewer lead prior to the right-of-way to comply with the City's Industrial Pretreatment Program. Please coordinate location and specific requirements with Matt Griffith, Utility Superintendent.

Additional sewer and water equity fees will be required.

A permit may be necessary from the county drain commissioner.