

**RESOLUTION NO. 2018-19**

**A RESOLUTION TO AUTHORIZE THE REPAIR OF A PUMP FOR THE LANSING LIFT STATION**

**WHEREAS**, the Lansing Lift Station is the second largest sewage pump station in the City; and

**WHEREAS**, the pump was initially installed approximately ten years ago; and

**WHEREAS**, there are two pumps in the lift station with one backup pump; and

**WHEREAS**, the pump was removed due to a failure and taken to Jett Pump & Valve, LLC for evaluation and a cost estimate to fix; and

**WHEREAS**, once partially disassembled, Jett Pump & Valve estimated the cost to fix the pump is \$6,283.21; and

**WHEREAS**, once fully disassembled, Jett Pump & Valve will seek approval of the Director of Public Works prior to incurring any additional costs; and

**WHEREAS**, the only the cost of a new Homa pumps is approximately \$19,000.00; and

**WHEREAS**, we feel that this pump will continue to serve us well if it is rebuilt; and

**WHEREAS**, Section 2-178 of the City Ordinances allows for the waiver of sealed bids.

**THEREFORE, BE IT RESOLVED** That the City Council approve the rebuilding of the Lansing Lift Station pump by Jett Pump & Valve, LLC and agrees to waive the sealed bid process.