

Memo

To: Bryan Myrkle, Community Development
From: Amy E. Gilson, P.E., Director of Public Works
Date: January 4, 2019
Re: Taco Bell Site Plan Review



We have reviewed the above referenced site plan as it relates to our standards and codes, and offer the following comments:

Reconnection to the watermain and sanitary sewer must be witnessed by the City. Pressure tests must also be witnessed by DPW staff. A minimum 24 hour notice is required.

Please coordinate the removal and replacement of the water meter and touch pad with the DPW. A minimum 24 hour notice is required. Unless there is a change in meter size, there will be no additional fees required.

Tracer wire shall be provided on all plastic service lines.